



- NOTES:
1. ALL PVC SERVICE LATERALS SHALL HAVE A CONTINUOUS STRIP OF METAL TRACER TAPE INSTALLED 2' - 3' BELOW FINISH GRADE FROM CENTERLINE OF SANITARY SEWER TO ROW/EASEMENT.
 2. CURB MARKERS SHALL BE PROVIDED FOR SERVICE LATERALS. REFER TO SPECIFICATIONS - DESIGN CRITERIA FOR SERVICE LATERALS.
 3. PROVIDE REMOVABLE WATERTIGHT PLUG AS REQUIRED FOR TESTING PURPOSES AND PROTECTION OF LINE.(TYP.)

SERVICE CONNECTION FOR DEEP SEWER (MORE THAN 6')

NOT TO SCALE



SERVICE CONNECTION DETAILS FOR
DEEP SEWER (MORE THAN 6')

SD-25