



- NOTES:
1. ALL PVC SERVICE LATERALS SHALL HAVE A CONTINUOUS STRIP OF METAL TRACER TAPE INSTALLED 2' - 3' BELOW FINISH GRADE FROM CENTERLINE OF SANITARY SEWER TO ROW/EASEMENT.
  2. CURB MARKERS SHALL BE PROVIDED FOR SERVICE LATERALS. REFER TO SPECIFICATIONS - DESIGN CRITERIA FOR SERVICE LATERALS.
  3. PROVIDE REMOVABLE WATERTIGHT PLUG AS REQUIRED FOR TESTING PURPOSES AND PROTECTION OF LINE.(TYP.)

## SERVICE CONNECTION FOR SHALLOW SEWER (6' OR LESS)

NOT TO SCALE



SERVICE CONNECTION DETAILS FOR SHALLOW SEWER (LESS THAN 6')

SD-26